

PLANNING COMMITTEE

14TH DECEMBER 2021

ADDENDA AND CORRECTIONS

REFERENCE NO.	PAGE	ADDENDA AND CORRECTIONS
PART A		
21/0927/FUL		Additional Consultation Responses:
	18	<u>Worcestershire Regulatory Services (Air Quality)</u> – No Objections subject to air quality mitigation measures of secure car parking and electric vehicle charging points. The AQA is acceptable and WRS agree with the methodology and conclusions, therefore WRS have no adverse comments for Air Quality.
	18	<u>Countryside and Parks Manager</u> – The ecological assessment is appropriate and it is considered that with adequate mitigation, secured by condition, that no adverse impact will occur to protected species. The Applicant needs to consider Biodiversity net gain on site.
	25	Paragraph 5.2 – Condition 23 should read “Use of building limited to educational establishment only”
	11	Applicant is Department of Education
PART B		
21/0605/FUL		Corrections:
	32	Paragraph 4.15 should be 4.12.

		Additional Conditions/Information:
	28	<u>Kidderminster Town Council</u> – No Objections
	32	Officer Comment – Following further discussions with the Applicant, consideration is being given to alternative or renewal energy and power sources as part of the development. No details have been submitted but this can be adequately dealt with by way of a suitable condition.
	33	Additional Condition; 15. Scheme of for sustainable energy and/or power to be submitted.